



**पश्चिमांचल विद्युत वितरण निगम लि०,
विक्टोरिया पार्क, मेरठ**

पत्रांक **1136**/वि०का०शा०मं०/मे०/निविदा

दिनांक **03-10-2023**

संशोधन

इस कार्यालय द्वारा आमंत्रित **अल्पकालीन** ई-निविदा सं० **29**/2023-24/वि०का०शा०मं०/मेरठ में अंकित सामग्री HT Bushing Rod, made of Brass, suitable for 250/400/630 KVA हेतु Guaranteed Technical Particulars को सलंगनकानुसार संशोधित किया जाता है। उपरोक्त ई-निविदा अब दिनांक 10-10-2023 को निर्धारित समय पर खोली जायेगी। निविदा की अन्य नियम व शर्तें यथावत रहेगी। निविदा से सम्बन्धित अन्य समस्त विस्तृत विवरण/जानकारी/संशोधन/तिथि विस्तार इत्यादि हेतु वेबसाईट <https://etender.up.nic.in> लॉग इन करें।

अधीक्षण अभियन्ता
विद्युत कार्यशाला मण्डल,
मेरठ

Revised

Guaranteed Technical Particulars for Supply of H.T Brass Bushing Rod for 160 /250/400/630/1000 KVA Transformer and as per IS 3347 PART -1/SEC 2/1979 (with its latest amendment if any) against E-Tender No. 29(2023-24)/EWC/Mrt

Sl.	Item	H.T Brass Bushing Rod as pre IS 3347 PART -1/SEC 2/1979 with latest amendment.
1	Rating	For 160 /250/400/630/1000 KVA Transformer
2	Material	Brass
3	Total Length of Stem	135 mm
4	Dia Meter of Rod	11.8 mm
5	Brass Cap M-12	1 No.
6	Hex M-12 lock Nut (Brass)	03 Nos. (Dia 19 mm)
7	Washer M6 (Brass)	1 No.
8	MS Hex Screw (M-6)	01 No.
9	Neoprene Oil Seals M-12	01 No.
10	Weight of Stem with collar (Brass)	155 gm.
11a	Brass Cap Size	I.D 45.1 mm, O.D 47.6 mm, Bore 12.7 mm, Height 22.7 mm
11b	Weight of Brass Cap	70 gm.
12	Weight of Hex Nut and washer (Brass)	35 gm
13	Total Minimum Brass Weight	260 gm.
14	Tolerance	± 1.5% (No Negative Tolerance in Brass weight)

**Signature of Tenderer
With Seal**