

**SCHEDULE I-A OF GUARANTEED TECHNICAL PARTICULARS FOR SUPPLY OF
OUTDOOR TYPE SINGLE PHASE 11/ 0.250 ALUMINUM WOUND DISTRIBUTION
TRANSFORMERS OF 10 KVA RATING WITH OIL IMMERSSED CIRCUIT BREAKER.**

| | | |
|------|---------------------------------|---|
| S.N. | Particulars | : |
| A. | Name of Manufacturer & | : |
| B. | Place of manufacture | : |
| C. | Make | : |
| 1. | Name of Tenderer | : |
| 2. | Type : | |
| 3. | Rating | : |
| | (a) Rated output (KVA) | : |
| | (b) Rated voltage-H.V. (Volts) | : |
| | (c) Rated Voltage-L.V. (Volts) | : |
| | (d) No load voltage ratio | : |
| | (e) No. of phases | : |
| | (f) Frequency (c/s) | : |
| 4. | Method of Cooling Radiator type | : |
| 5. | Internal Dimensions of Tank | |
| | (a) Length (mm) | : |
| | (b) Breadth (mm) | : |
| | (c) Height (mm) | : |
| | (d) Thickness of tank sheets : | |
| | (i) Sides (mm) | : |
| | (ii) Top & Bottom (mm) | : |

6. DETAILS OF CORE

- (a) Diameter (mm) :
- (b) Window Height (mm) :
- (c) Limb Center (mm) :
- (d) Width of the main step :
- (e) Whether yoke is plain or stepped inside window :
- (f) Cross Sectional Area (sq.mm.) :
 - (i) Gross :
 - (ii) Nett :
(Staking factor of 0.97 shall be taken)
- (g) Working flux density at rated voltage & frequency (Tesla) actual as per your design. :
- (h) Over fluxing without saturation :
(Curve to be furnished by the manufacturer in support of his claim)
- (i) Insulation Material provided for core :
- (j) Grade of Material & Thickness of Lamination used (mm) :
- (k) Total min.weight of stamping used in core and yoke (kg.) :
(Please furnish core weight calculations, details of core steps and its drawing)

7. H.V. COIL CONSTRUCTION DETAILS :

- (a) Type of winding :
- (b) Type & Size of Conductor (Bare) mm :
- (c) Size of conductor insulated(mm) :
- (d) Cross Sectional area of Conductor (mm²)
 - (i) Gross :

- (ii) Nett :
- (e) No. of Coils per Limb :
- (f) Outer Diameter of Coil (mm) :
- (g) Inner Diameter of Coil (mm) :
- (h) Mean Diameter of Coil (mm) :
- (i) Insulation of Conductor :
- (j) Interlayer reinforcement details :
 - i) Top & bottom layer :
 - ii) In between all layers :
 - iii) End turn insulation :
 - iv) Whether wedges are provided at 50% turns of HV coil. :
- (k) Current at full load (Amp) :
- (l) Working current density as per your design (Amp/Sq.mm) :
- (m) Weight of bare conductor used in one leg of H.V. (Kg.) :
- (n) Weight of insulated conductor used in one leg of H.V. (Kg.) :
- (o) No. of turns per leg :
- (p) Length of mean turns (mm) :
- (q) Resistance of winding (with 5% tolerance)
 - a) at 20 °C (Ohms) :
 - b) at 75 °C (Ohms) :
- (r) I^2R at 75°C. :
- (s) Axial Length (mm) :
- (u) Weight of oil soaked coils in one leg :

8. L.V. COIL CONSTRUCTION DETAILS :

- (a) Type of Winding :
- (b) Type, Number and Size of bare conductor. :
- (c) Size of insulated conductor :
- (d) Cross sectional area of bare conductor (sq.mm.)
 - (i) Gross :
 - (ii) Net As per IS:6160 :
- (e) No. of coils per limb :
- (f) Outer diameter of coil (mm) :
- (g) Inner Diameter of Coil (mm) :
- (h) Mean Diameter of Coil (mm) :
- (i) Insulation of Conductor :
- (j) Inter layer reinforcement details :
- (k) Current at full load (Amp) :
- (l) Current density as per your design (A/mm²) :
- (m) End turn insulation :
- (n) Weight of bare conductor used in one leg of LV (kg) :
- (o) Weight of insulated conductor used in one leg of LV (kg.) :
- (p) No. of turns per leg :
- (q) Length of mean turns (mm) :
- (r) Resistance of winding (with 5% tolerance)
 - a) at 20 °C (Ohms) :

- b) at 75 °C (Ohms) :
- (s) I^2R at 75°C :
- (t) Axial Length (mm) :
- (u) Weight of oil soaked coil in one leg :

9. INSULATION DETAILS MATERIAL AND SIZE

- (a) H.V. Coil end packing :
- (b) L.V. coil end packing :
- (c) Inter coil spacer of HT sections :
- (d) Bottom yoke strip insulation at
foot plate :
- (e) Yoke Insulation :
- (f) Clamp Insulation :
- (g) Inter Phase Barrier :
- (h) Core Wrap :
- (i) Cylindrical Insulation Between
H.T. & L.T. :
- (j) Type of blocks used in between coils :
- (k) Weight of total insulating material
in one T/F (oil soaked). :

(Enclose calculation of losses with complete details of factors assumed)

10. **DETAILS OF CLEARANCES (mm)**

- (a) Internal clearance between inner
walls of Tank & core coil
assembly unit
 - (i) On length(Bushing side) :
 - (ii) On Breadth Side(Non bushing side) :
- (b) Radial clearance between H.V. :

& L.V. Winding

- (c) Phase of phase clearance between :
H.V. Limb
- (d) Clearance from top of the live part of :
top changer to the inside of the top
cover of the tank.
- (e) Radial clearance of L.V. coil :
from core.
- (f) Minimum clearance between LV
Pole to earth)
- (g) Horizontal duct between H.T. :
Section coil
- (h) End clearance of H.T. coil from :
Yoke (With angle shaped windings)
- (i) Minimum clearance between core
& tank bottom.
- (j) Angular ducts between LT & HT winding.

Note: Above clearances include the thickness of insulation.

**11. IMPULSE TEST VOLTAGE OF WINDING FOR 1.2/50 M.S. WAVE
ACCORDING TO RELEVANT ISS :**

- (a) H.V. (KVP) :
- (b) L.V. (KVP) :
- 12. Volts per coil of H.V. Winding (Volts) :
- 13. Approximate volts per layer of H.V.
winding (Volts) :
- 14. Performance reference temperature (°C) :
- 15. Core loss in watts (Guaranteed value without
any positive tolerance) (Watts)
 - a) Normal Voltage :
 - b) Maximum Voltage :
- 16. Full Load losses at 75 °C (Watts) :

(Guaranteed value without any positive tolerance)

17. Load loss at 50% load & at 75 °C :
(Guaranteed value without any positive tolerance)
18. Total Losses at 100% load at 75 °C (Watts) :
(Guaranteed value without any positive tolerance)
19. Total losses at 50% load at 75 °C :
(Guaranteed value without any positive tolerance)
20. Magnetising (No Load) Current at
 - a) 90% Voltage :
 - b) 100% Voltage :
 - c) 110% Voltage :
21. Regulation at normal full load and
 - a) Unity P.F. and :
 - b) 0.8 P.F. :
22. Impedance voltage at rated voltage :
& frequency at 75°C.
23. Percentage reactance at rated voltage :
& frequency at 75°C.
24. Percentage resistance at 75°C. :
25. **PERCENTAGE IMPEDANCE AT 75°C.**
 - (a) With respect to high voltage :
 - (b) With respect to low voltage :
26. Un-balance current as percentage of :
full load current
27. **Efficiency at 75 °C**
 - a) Unity P.F. and :
 - b) 0.8 P.F.

- i) 125% load :
 - ii) 100% load :
 - iii) 75% load :
 - iv) 50% load :
 - v) 25% load :
28. Permissible duration of overload following Continuous running at normal rated load in Ambient temperature of 50°C.
- (a) 10% overload :
 - (b) 20% overload :
 - (c) 30% overload :
29. RMS value of symmetrical short circuit current which the transformer can withstand and its duration according to clause 9.1 of ISS:2026 or CL:1001 of BSS with latest amendment thereof. :
30. Increase in temperature of winding at full load by resistance method in an ambient temperature of 50°C. :
31. Increase in temperature of oil by thermometer at full load in an ambient temperature of 50°C. :
32. Temperature of hottest spot in the winding at full load in an ambient temperature of 50°C. :
33. Terminal arrangement of H.V. side :
34. Terminal arrangement of L.V. side :
35. **PARTICULARS OF H.V. BUSHING** :
- (a) Name of Manufacturer :
 - (b) Type :
 - (c) Confirming to ISS :

- (d) Dry withstand voltage for one minute :
- (e) Wet withstand voltage for 30 minutes :
- (f) Voltage rating :
- (g) Impulse withstand voltage
1/50 μ sec. wave :
 - (i) Positive :
 - (ii) Negative :
- (h) Total creepage distance in air (mm) :
- (i) Height of bushing above transformer tank. :
- (j) Material & Size of HV terminal spends.

36. **PARTICULARS OF L.V./ NEUTRAL BUSHING :**

- (a) Name of Manufacturer :
- (b) Type :
- (c) Confirming to ISS :
- (d) Voltage rating :
- (e) Dry withstand voltage for 1 minute :
- (f) Wet Withstand voltage for 30 min. :
- (g) Total creepage distance in air (mm) :
- (h) Material and Size of LT terminal studs :

37. Time constant of transformer :

38. Radiation

- i) Heat dissipation by tank walls :
(excluding top & bottom)
- ii) Heat dissipation by cooling tubes :
- iii) Diameter and thickness of cooling Tubes :
- iv) Whether calculation sheet for selecting cooling area to ensure that the transformer is capable of giving continuous rated :

output without exceeding temperature
rise is enclosed.

39. **TRANSFORMER OIL**

- (a) Grade of Oil :
- (b) Dielectric strength :
- (c) Resistivity :
- (d) Acidity :
- (e) Tan Delta :
- (f) Name of Supplier (only reputed make :
shall be accepted)

40. **Quantity of transformer oil**

- a) First filling :
- b) Drained out :

41. **WEIGHT OF THE FOLLOWING**

- (a) Tank & Fitting (Kg) :
- (b) Core coil assembly (Kg) :
- (c) All HV & LV coil (Kg) :
- (d) Core stampings(only) (Kg) :
- (e) Transformer oil (Kg) :
- (f) Total weight of transformer
including oil (Kg.) :

42. **OVERALL DIMENSIONS OF
TRANSFORMER**

- (a) Length (mm) :
- (b) Breadth (mm) :
- (c) Height (mm) :

43. Conservator dimensions :

44. Name of material, number, weight :
and size used for clamping of core

& winding

- (a) Core Clamp :
- (b) Tie Rod :
- (c) Core Bolt :
- (d) Bottom Foot Plate :

45. Line lead support details

46. Silica Gel breather size:

47. Clearance in air between :

- (a) Phase to Phase (HV Side) :
- (b) Phase to Earth (HV Side) :
- (c) Phase to Phase (LV) side
- (d) Phase to Earth (LV Side) :

48. Type Testing:

(a) Is the offered 11/0.4 KV Conventional :
Type (3 Star rated) Distribution Transformer type tested?

(b) If yes, when and where it was Type Tested? :

(b) Is there any deviation in the technical specifications :
of offered transformer, if yes give details

(d) Details of type test reports:

| | Name of test | Date of test | Whether test report enclosed or not (Y/N) | If yes no. of sheets enclosed |
|---|------------------------------------------------------------|--------------|-------------------------------------------|-------------------------------|
| 1 | Impulse voltage withstand test at 95 KVP | | | |
| 2 | Temperature rise test | | | |
| 3 | Short circuit withstand test: Thermal and dynamic ability. | | | |

| | | | | |
|---|-----------------------------------------------|--|--|--|
| 4 | Magnetic Balance Test. | | | |
| 5 | Air Pressure Test: As per IS – 1180. | | | |
| 6 | Noise-level measurement. | | | |
| 7 | Un-balanced current test: | | | |
| 8 | Measurement of zero-phase sequence impedance. | | | |
| 9 | Measurement of Harmonics of no-load current | | | |

49. Whether you will use specified Aluminium alloy or brass/ copper with suitable bimetallic arrangement for HV/LV connector? Yes/No
50. Have you submitted drawings and calculations of cross sectional area of core? Yes/No
51. Have you submitted calculation for computation of losses 100% and 50% load at 75 deg. C. as per design data of offered transformer? Yes/No
52. Whether the name plate gives all particulars : Yes/No
As required in tender?
53. Whether the offer confirms to the limits of : Yes/No
Temperature rise mentioned in the specification
54. Details of LT Bushing Side Bus Bar Arrangement
- a. L.T Strip Size (mm)
 - b. Bakelite strip size (mm)
 - c. Al. Lugs size (mm)
 - d. External phase to phase clearance between Al. Strips (mm)
 - e. Whether bushing rod connected to Al. Strip by Nut-Bolt of 12 mm size of brass material Yes/No
 - f. Whether Al. Strip connected to Al. Lugs by M.S. galvanized Nut-Bolt of 12 mm size Yes/No
 - g. Whether Bakelite strip is properly fixed with tank wall by suitable nut-bolts. Yes/No

55. Details of External H.T Fuse unit arrangement to be provided on H.T side Bushing of transformer
- Glass Fiber strip size (mm)
 - H.T, Connector size (Adjustable)mm
 - External phase to phase clearance between glass fiber strips (mm)
 - Break Down voltage of Glass Fiber strips (KV)
56. Whether engraving of Unique. No. (letter /digit size approx 10mm & engraving depth approx 0.5 mm) on the top channel of core coil assembly & on inside portion of top cover of transformer shall be done. Yes/No
57. Whether MS Plate of size $150 \times 100 \times 2$ mm shall be continuously welded on the same side wall on which name plate is fixed. Yes/No
58. Whether engraving of name of firm, Unique No, Rating of transformer, PO NO and Date of inspection etc on M.S Plate (as per above column no. 56) as per approved Drawing shall be done. Yes/No

IMPORTANT NOTES :

- CROSS SECTIONAL AREA OF CORE IS TO BE SUBSTANTIATED BY DRAWINGS AND CALCULATIONS.
- MAXIMUM FLUX DENSITY AT RATED VOLTAGE AND FREQUENCY IS TO BE SUPPORTED BY CALCULATIONS.
- WEIGHT OF STAMPINGS IN CORE ASSEMBLY MUST BE SUBSTANTIATED BY CALCULATIONS.
- COMPUTATION OF NO LOAD CURRENT AT 90%, 100% AND 110.0% MAY BE SUPPORTED BY CALCULATIONS.
- COMPUTATION OF NO LOAD AND FULL LOAD LOSS AT 75 DEG.C. MAY BE SUPPORTED BY CALCULATIONS.
- DETAILS OF CLEARANCES AS GIVEN IN CLAUSE: 11 INCLUDE THICKNESS OF.

SCHEDULE IB
ADDITIONAL DETAILS

| Sl. No. | Description | |
|---------|------------------------------------------------|----------|
| 1. | Core Grade | |
| 2. | Core diameter | mm |
| 3. | Gross core area | sq cm |
| 4. | Net core area | sq cm |
| 5. | Flux density | Tesla |
| 6. | Mass of core | kg |
| 7. | Loss per kg core at the specified flux density | watt |
| 8. | Core window height | mm |
| 9. | Center to center distance o the core | mm |
| 10. | No. of LV Turns | |
| 11. | No. of HV Turns | |
| 12. | Size of LV conductor bare/covered | mm |
| 13. | Size of HV conductor bare/covered | mm |
| 14. | No. of parallels | |
| 15. | Current density of LV winding | A/sq mm. |
| 16. | Current density of HV winding | A/sq mm. |
| 17. | Wt. of the winding for Transformer | kg |
| 18. | Wt. of the HV winging of Transformer | kg |
| 19. | No. of LV Coils/phase | |
| 20. | No. of HV Coils/phase | |
| 21. | Height of LV Windings | mm |
| 22. | Height of HV Windings | mm |
| 23. | ID/OD of HV winding | mm |
| 24. | ID/OD of LV winding | mm |
| 25. | Size of the duct in LV winding | mm |
| 26. | Size of the duct in HV winding | mm |
| 27. | Size of the duct between HV and LV | mm |
| 28. | HV winding to tank LV winding clearance | mm |
| 29. | HV winding to tank clearance | mm |
| 30. | Calculated impedance | % |
| 31. | HV to earth creepage distance | mm |
| 32. | LV to earth creepage distance | mm |