

Validate

Print

Help

Tender Inviting Authority: Superintending Engineer, EUDC-II, Ghaziabad (U.P)

Item Rate BoQ

Name of Work: विद्युत नगरीय विद्युत माइक्रो-द्वितीय, गाजियाबाद के कार्यक्षेत्र में विजनेस प्लान वर्ष 2023-24 के मर में सी-टर्की के आधार पर 11 केशी/एलटीडी लाईन की अपडेटाउण्ड केवल डालना और कार्य ई-निविदा द्वारा बाह्य एजेंसी के माध्यम से कराने के सम्बन्ध में।

Contract No: 0120 2607114

Name of the
Bidder/
Bidding Firm /
Company :

(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only) GST EXTRA as applicable

PRICE SCHEDULE FOR E-TENDER NO-12/M/2023-24/EUDC-2/GZB

NUMBER #	TEXT #	Item Description	NUMBER	TEXT #	Quoted Currency in INR / Other Currency	BASIC RATE in Figures To be entered by the Bidder Rs. P	TOTAL AMOUNT Without Taxes	TOTAL AMOUNT In Words	TEXT #
Sl. No.			Quantit y	Units					
1	2	विद्युत नगरीय विद्युत माइक्रो-द्वितीय, गाजियाबाद के कार्यक्षेत्र में विजनेस प्लान वर्ष 2023-24 के मर में सी-टर्की के आधार पर 11 केशी/एलटीडी लाईन की अपडेटाउण्ड केवल डालना और कार्य ई-निविदा द्वारा बाह्य एजेंसी के माध्यम से कराने के सम्बन्ध में।	3	4	5	6	7	8	
1.00		अपडेटाउण्ड केवल डालना और कार्य ई-निविदा द्वारा बाह्य एजेंसी के माध्यम से कराने के सम्बन्ध में।							
1.01		Safe Carriage of ST Pole 11 Meter long from store Center Ghaziabad /Sahibabad /Noida to site of work including loading and unloading at both end and Erection/Installation of poles including all accessories. Complete work as per requirement of site.	2	No.	INR			0.00	INR Zero Only
1.02		Safe Carriage of 11 KV XLPE Cable 3x185 Sq.mm from store Center Ghaziabad /Sahibabad /Noida to site of work including loading and unloading at both end.	2486	Mtr.	INR			0.00	INR Zero Only
1.03		Safe Carriage of 11 KV XLPE Cable Box/Joining Kit 3x185 Sq.mm (Outdoor) from store Center Ghaziabad /Sahibabad /Noida to site of work including loading and unloading at both end and fixing the same as per requirement of site.	42	No.	INR			0.00	INR Zero Only
1.04		Safe Carriage of 22 No. 11 KV Composite Polymeric Pin Insulator from store Center Ghaziabad /Sahibabad /Noida to site of work including loading and unloading at both end.	22	No.	INR			0.00	INR Zero Only
1.05		Laying of underground 11 KV XLPE Size 3x185 Sq.mm. Cable. Drilling of Dia 160 mm in Two Panel Bore By Trenchless Method by Horizontal Boring at DEPTH of 1.6 to 2 Mtr. below Ground level in Hot Mixed Road with HDPE Pipe 160 mm dia (HDPE Pipe shall be Provided by the contractor). Complete the work as per requirement of site/RESPO manual.	1300	Mtr.	INR			0.00	INR Zero Only
1.06		Laying of underground 11KV XLPE Size 3x185 Sq.mm. Cable with sand and brick. Complete the work as per requirement of site/RESPO manual.	650	Mtr.	INR			0.00	INR Zero Only
1.07		Providing and fixing of Sundary Items	120	Kg.	INR			0.00	INR Zero Only
1.08		Providing and fixing of 24 Volts Battery for 33/11 KV Sub-Station Pannel as per details given below :- A) Battery Set 24 Volts as per sample. Battery/Guarantee :- Minimum 03 years on site replacement guarantee	4	No.	INR			0.00	INR Zero Only
1.09		Providing and fixing of 24 Volts Battery Charger for 33/11 KV Sub-Station Pannel as per details given below :- A) Battery Charger 24 Volts as per sample. Type-FCBC, Input- 110-330. Battery Capacity-200 Amp.	5	No.	INR			0.00	INR Zero Only
2.00		Providing and fixing of Sundary Items A) G.I. Pipe 6" DIA.	12	Mtr.	INR			0.00	INR Zero Only
2.01		Providing Henley Type LT Tailless Fuse Unit 800 Amp. & installation after making suitable structure. Complete the work as per requirement of site/RESPO norms.	50	No.	INR			0.00	INR Zero Only
2.02		Providing of Transformer Trolley suitable for 400 KVA Transformer with weight carrying capacity of 5 Ton. Specification are as under:- Length-10 Feet, Width-6 Feet, Height-7 Feet, Base Chasis size-150mm x 75mm of C Type Channel Cross Channel over chasis should be of Min. 100 mm x 50 mm size having at least six cross members and two longitudinal members. M.S. angle65x65x6 In all four sides with Fencing M.S. Angle of 40x25x4mm in the middle of each side size of fencing 10x6x7 (Top side open) with 8 SWG GI Wire. M.S. Sheet 6 mm. Wheel hub heavy duty of 08 holes with banded wheels bearings. Wheel (double plated ring tyewwith 8 holes) and accordingly type should be size 9x20 (16 Pilot branded like JK/MRF/APOLLO/GOOD YEAR should be double plate made of I.E. one wheel RIM should have two plates. Trolley hitch suitable for movement both sides. One coat of Red Oxide and 2 coat of super synthetic enamel paint. (Sample can be seen at 33/11 KV Sub-Station Sector-16 Vasundhara, Ghaziabad).	5	No.	INR			0.00	
Total in Figures							0.00	INR Zero Only	
Quoted Rate in Words							INR Zero Only		